

# CONSOLIDATED MUTUAL MAPLE GROVE 2026 Drinking Water Quality Report

## Covering Data For Calendar Year 2025

*Public Water System ID: CO0130020*

Esta es información importante. Si no la pueden leer, necesitan que alguien se la traduzca.

We are pleased to present to you this year's water quality report. Our constant goal is to provide you with a safe and dependable supply of drinking water. Please contact CHRISTOPHER JONES at 303-274-7410; 303-238-0451 with any questions or for public participation opportunities that may affect water quality. **Water quality data from our wholesale supplier (Denver Water) treatment plants is integrated within this report. A complete copy of Denver Water's Consumer Confidence Report will be posted on their website when it is available (<https://www.denverwater.org/your-water/water-quality/water-quality-reports>).**

### General Information

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791) or by visiting [epa.gov/ground-water-and-drinking-water](https://www.epa.gov/ground-water-and-drinking-water).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA Safe Drinking Water Hotline at (1-800-426-4791).

### Contaminant Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- **Microbial contaminants:** viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- **Inorganic contaminants:** salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides:** may come from a variety of sources, such as agriculture, urban storm water runoff, and residential uses.
- **Radioactive contaminants:** can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants:** including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, the Colorado Department of Public Health and Environment prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

### Lead in Drinking Water

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. We are responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time.

You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly.

Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact CHRISTOPHER JONES at 303-274-7410; 303-238-0451. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at [epa.gov/safewater/lead](http://epa.gov/safewater/lead).

## Service Line Inventory

New state and federal laws require us to inventory all water service lines in our service area to classify the material. A service line is the underground pipe that carries water from the water main, likely in the street, into your home or building. If you would like to view a copy of our service line inventory or have questions about the material of your service line, contact CHRISTOPHER JONES at 303-274-7410; 303-238-0451.

## Source Water Assessment and Protection (SWAP)

The Colorado Department of Public Health and Environment may have provided us with a Source Water Assessment Report for our water supply. For general information or to obtain a copy of the report please visit [wqcdcompliance.com/ccr](http://wqcdcompliance.com/ccr). The report is located under “Guidance: Source Water Assessment Reports”. Search the table using our system name or ID, or by contacting CHRISTOPHER JONES at 303-274-7410; 303-238-0451. The Source Water Assessment Report provides a screening-level evaluation of potential contamination that *could* occur. It *does not* mean that the contamination *has or will* occur. We can use this information to evaluate the need to improve our current water treatment capabilities and prepare for future contamination threats. This can help us ensure that quality finished water is delivered to your homes. In addition, the source water assessment results provide a starting point for developing a source water protection plan. Potential sources of contamination in our source water area are listed below. Please contact us to learn more about what you can do to help protect your drinking water sources, any questions about the Drinking Water Quality Report, to learn more about our system, or to attend scheduled public meetings. We want you, our valued customers, to be informed about the services we provide and the quality water we deliver to you every day. Our groundwater drinking water sources, if any, are located in JEFFERSON county near our water system.

## Our Water Sources

Sources (Water Type - Source Type)	Potential Source(s) of Contamination
For Consolidated Mutual Water Company's Maple Grove Water Treatment Plant	
<p>FAIRMOUNT RESERVOIR INTAKE (Surface Water-Intake)</p> <p>WELTON RESERVOIR INTAKE (Surface Water-Intake)</p> <p>SMART RESERVOIR (Surface Water-Reservoir) PURCHASED FROM CO0116001 (Surface Water-Consecutive Connection)</p> <p>MAPLE GROVE RESERVOIR INTAKE (Surface Water-Intake)</p>	<p>EPA Hazardous Waste Generators, EPA Toxic Release Inventory Sites, Aboveground, Underground and Leaking Storage Tank Sites, Existing/Abandoned Mine Sites, Other Facilities, Commercial/Industrial/Transportation, High Intensity Residential, Low Intensity Residential, Urban Recreational Grasses, Row Crops, Fallow, Pasture / Hay, Deciduous Forest, Septic Systems, Road Miles</p>
For Denver Water's Treatment Plants	
<p>MARSTON FOREBAY (Surface Water-Intake)</p> <p>STRONTIA SPRINGS RES INTAKE (Surface Water-Intake)</p> <p>RALSTON RESERVOIR INTAKE (Surface Water-Intake)</p> <p>S PLATTE DIVERSION CONDUIT 20 (Surface Water-Intake)</p>	<p>EPA Abandoned Contaminated Sites, EPA Hazardous Waste Generators, EPA Chemical Inventory/Storage Sites, EPA Toxic Release Inventory Sites, Permitted Wastewater Discharge Sites, Aboveground, Underground and Leaking Storage Tank Sites, Solid Waste Sites, Existing/Abandoned Mine Sites, Other Facilities, Commercial/Industrial/Transportation, High Intensity Residential, Low Intensity Residential, Urban Recreational Grasses, Quarries / Strip Mines / Gravel Pits, Row Crops, Fallow, Pasture / Hay, Deciduous Forest, Evergreen Forest, Mixed Forest, Septic Systems, Oil / Gas Wells, Road Miles</p>

## Terms and Abbreviations

- **Maximum Contaminant Level (MCL)** – The highest level of a contaminant allowed in drinking water.
- **Treatment Technique (TT)** – A required process intended to reduce the level of a contaminant in drinking water.
- **Health-Based** – A violation of either a MCL or TT.
- **Non-Health-Based** – A violation that is not a MCL or TT.
- **Action Level (AL)** – The concentration of a contaminant which, if exceeded, triggers treatment and other regulatory requirements.
- **Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Contaminant Level Goal (MCLG)** – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Violation (No Abbreviation)** – Failure to meet a Colorado Primary Drinking Water Regulation.
- **Formal Enforcement Action (No Abbreviation)** – Escalated action taken by the State (due to the risk to public health, or number or severity of violations) to bring a non-compliant water system back into compliance.
- **Variance and Exemptions (V/E)** – Department permission not to meet a MCL or treatment technique under certain conditions.
- **Gross Alpha (No Abbreviation)** – Gross alpha particle activity compliance value. It includes radium-226, but excludes radon 222, and uranium.
- **Picocuries per liter (pCi/L)** – Measure of the radioactivity in water.
- **Nephelometric Turbidity Unit (NTU)** – Measure of the clarity or cloudiness of water. Turbidity in excess of 5 NTU is just noticeable to the typical person.
- **Compliance Value (No Abbreviation)** – Single or calculated value used to determine if regulatory contaminant level (e.g. MCL) is met. Examples of calculated values are the 90<sup>th</sup> Percentile, Running Annual Average (RAA) and Locational Running Annual Average (LRAA).
- **Average (x-bar)** – Typical value.
- **Range (R)** – Lowest value to the highest value.
- **Sample Size (n)** – Number or count of values (i.e. number of water samples collected).
- **Parts per million = Milligrams per liter (ppm = mg/L)** – One part per million corresponds to one minute in two years or a single penny in \$10,000.
- **Parts per billion = Micrograms per liter (ppb = ug/L)** – One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **Not Applicable (N/A)** – Does not apply or not available.

- **Level 1 Assessment** - A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- **Level 2 Assessment** - A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

## Detected Contaminants

CONSOLIDATED MUTUAL MAPLE GROVE routinely monitors for contaminants in your drinking water according to Federal and State laws. The following table(s) show all detections found in the period of January 1 to December 31, 2025 unless otherwise noted. The State of Colorado requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one-year-old.

**Note:** Only detected contaminants sampled within the last 5 years appear in this report. If no tables appear in this section, then no contaminants were detected in the last round of monitoring.

## Disinfectants Sampled in the Distribution System

**TT Requirement: At least 95% of samples per period (month or quarter) must be at least 0.2 ppm OR  
 If sample size is less than 40 no more than 1 sample is below 0.2 ppm  
 Typical Sources: Water additive used to control microbes**

Disinfectant Name	Time Priod	Results	Number of Samples Below Level	Sample Size	TT Violation	MRDL
Chloramine	2025 ,December	<b>Lowest period</b> percentage of samples meeting TT requirement: 100%	0	80	No	4.0 ppm

## Lead and Copper Sampled in the Distribution System

[Lead and copper individual sample results for 01/16/25 to 06/03/2025](#)

[Lead and copper individual sample results for 07/25/25 to 12/03/2025](#)

Contaminant Name	Time Period	Tap Sample Range Low - High	90 <sup>th</sup> Percentile	Sample Size	Unit of Measure	90 <sup>th</sup> Percentile AL	Sample Sites Above AL	90 <sup>th</sup> Percentile AL Exceedance	Typical Sources
Copper	01/16/2025 to 06/03/2025	0.004 to 0.195	0.14	60	ppm	1.3	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead	01/16/2025 to 06/03/2025	0 to 41.0	5	60	ppb	15	2	No	Corrosion of household plumbing systems; Erosion of natural deposits
Copper	07/25/2025 to 12/03/2025	0.009 to 0.361	0.06	60	ppm	1.3	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead	07/25/2025 to 12/03/2025	0 to 5.0	2	60	ppb	15	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

## Disinfection Byproducts Sampled in the Distribution System

Contaminant Name	Year	Average	Range Low - High	Sample Size	Unit of Measure	MCL	MCLG	MCL Violation	Typical Sources
Total Haloacetic Acids (HAA5)	2025	11.42	1.11 to 17.82	32	ppb	60	N/A	No	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM)	2025	21.36	14.67 to 37.72	32	ppb	80	N/A	No	Byproduct of drinking water disinfection
Chlorite	2025	0.36	0 to 0.73	12	ppm	1.0	0.8	No	Byproduct of drinking water disinfection

### Total Organic Carbon (Disinfection Byproducts Precursor) Removal Ratio of Raw and Finished Water

Contaminant Name	Year	Average	Range Low - High	Sample Size	Unit of Measure	TT Minimum Ratio	TT Violation	Typical Sources
If minimum ratio not met and no violation identified then the system achieved compliance using alternative criteria.								
<b>CMWC Maple Grove Water Treatment Plant</b>								
No sampling has been conducted within the past five years. The Total Organic Carbon (TOC) removal ratio requirement is not applicable to the CMWC Maple Grove Water Treatment Plant due to its utilization of Ultra Filtration technology.								
<b>Denver Water Treatment Plants</b>								
Total Organic Carbon Ratio	2025	1.21	1 to 1.65	33	Ratio	1.00	No	Naturally present in the environment
*If the minimum ratio is not met and no violation is identified, then the system achieved compliance using alternative criteria.								

### Summary of Turbidity Sampled at the Entry Point to the Distribution System

Contaminant Name	Sample Date	Level Found	TT Requirement	TT Violation	Typical Sources
<b>CMWC Maple Grove Water Treatment Plant</b>					
Turbidity	Date/Month: May	Highest single measurement: 0.06 NTU	Maximum 0.5 NTU for any single measurement	No	Soil Runoff
Turbidity	Month: Dec	Lowest monthly percentage of samples meeting TT requirement for our technology: 100%	In any month, at least 95% of samples must be less than 0.1 NTU	No	Soil Runoff
<b>Denver Water Treatment Plants</b>					
Turbidity	Date/Month: Mar	Highest single measurement: 0.17 NTU	Maximum 1 NTU for any single measurement	No	Soil Runoff
Turbidity	Month: Dec	Lowest monthly percentage of samples meeting TT requirement for our technology: 100%	In any month, at least 95% of samples must be less than 0.3 NTU	No	Soil Runoff

## Radionuclides Sampled at the Entry Point to the Distribution System

Contaminant Name	Year	Average	Range Low - High	Sample Size	Unit of Measure	MCL	MCLG	MCL Violation	Typical Sources
<b>CMWC Maple Grove Water Treatment Plant</b>									
Combined Radium	2025	0.1	0.1 to 0.1	1	pCi/L	5	0	No	Erosion of natural deposits
<b>Denver Water Treatment Plants</b>									
Gross Alpha	2024	0.9	0 to 2.7	5	pCi/L	15	0	No	Erosion of natural deposits
Combined Uranium	2024	0.1	0 to 1.4	24	ppb	30	0	No	Erosion of natural deposits

## Inorganic Contaminants Sampled at the Entry Point to the Distribution System

Contaminant Name	Year	Average	Range Low - High	Sample Size	Unit of Measure	MCL	MCLG	MCL Violation	Typical Sources
<b>CMWC Maple Grove Water Treatment Plant</b>									
Barium	2025	0.05	0.05 to 0.05	1	ppm	2	2	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium	2025	2	2 to 2	1	ppb	100	100	No	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride	2025	0.4	0.4 to 0.4	1	ppm	4	4	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Selenium	2025	4	4 to 4	1	ppb	50	50	No	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Contaminant Name	Year	Average	Range Low - High	Sample Size	Unit of Measure	MCL	MCLG	MCL Violation	Typical Sources
<b>Denver Water Treatment Plants</b>									
Barium	2025	0.03	0.02 to 0.05	33	ppm	2	2	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium	2025	0.26	0 to 1.8	33	ppb	100	100	No	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride	2025	0.55	0 to 0.75	33	ppm	4	4	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury	2025	0	0 to 0.12	33	ppb	2	2	No	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Nitrate	2025	0.09	0 to 0.19	33	ppm	10	10	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

## Secondary Contaminants

Secondary standards are non-enforceable guidelines for contaminants that may cause cosmetic effects (such as skin, or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water.

Contaminant Name	Year	Average	Range Low - High	Sample Size	Unit of Measure	Secondary Standard
<b>CMWC Maple Grove Water Treatment Plant</b>						
Sodium	2025	57.9	57.9 to 57.9	1	ppm	N/A
<b>Denver Water Treatment Plants</b>						
Sodium	2025	19.95	10.5 to 29.6	33	ppm	N/A

## Unregulated Contaminants

EPA has implemented the Unregulated Contaminant Monitoring Rule (UCMR) to collect data for contaminants that are suspected to be present in drinking water and do not have health-based standards set under the Safe Drinking Water Act. EPA uses the results of UCMR monitoring to learn about the occurrence of unregulated contaminants in drinking water and to decide whether or not these contaminants will be regulated in the future. We performed monitoring and reported the analytical results of the monitoring to EPA in accordance with its Unregulated Contaminant Monitoring Rule (UCMR). Once EPA reviews the submitted results, the results are made available in the EPA’s National Contaminant Occurrence Database (NCOD) ([epa.gov/dwucmr/national-contaminant-occurrence-database-ncod](http://epa.gov/dwucmr/national-contaminant-occurrence-database-ncod)) Consumers can review UCMR results by accessing the NCOD. Contaminants that were detected during our UCMR sampling and the corresponding analytical results are provided below. More information about the contaminants that were included in UCMR monitoring can be found at: [drinktaps.org/Water-Info/Whats-in-My-Water/Unregulated-Contaminant-Monitoring-Rule-UCMR](http://drinktaps.org/Water-Info/Whats-in-My-Water/Unregulated-Contaminant-Monitoring-Rule-UCMR). Learn more about the EPA UCMR at: [epa.gov/dwucmr/learn-about-unregulated-contaminant-monitoring-rule](http://epa.gov/dwucmr/learn-about-unregulated-contaminant-monitoring-rule) or contact the Safe Drinking Water Hotline at (800) 426-4791 or [epa.gov/ground-water-and-drinking-water](http://epa.gov/ground-water-and-drinking-water).

Contaminant Name	Year	Average	Range Low - High	Sample Size	Unit of Measure
N/A	N/A	N/A	N/A	N/A	N/A

## Violations, Significant Deficiencies, or Formal Enforcement Actions

Name	Description	Time Period	Describe the steps taken to resolve and the anticipated resolution date:
<b>CMWC Maple Grove Water Treatment Plant</b>			
None in 2025			
<b>Denver Water Treatment Plants</b>			
SYNTHETIC ORGANICS	FAILURE TO MONITOR AND/OR REPORT	01/01/2023 - 12/31/2025	Implemented proactive, plant-specific compliance sampling schedules to ensure continued regulatory adherence. Compliance collections for synthetic organic compounds and other nonroutine sampling requirements are now scheduled for the earliest available monitoring period.